e. Permit verification

Inspection Observations Verify the Permit		Yes	No	NA	NE
a.	Correct name and mailing address of permittee	Х			
b.	Correct name and location of receiving waters	Х			
C.	Product(s) and production rates conform with permit application (industries)	X			
d.	Flows and loadings conform with NPDES permit	Х			
e.	Treatment processes are as described in permit application/briefing memo	Х			
f.	New treatment process(es) added since last inspection		X		
g.	Notification given to state of new, different, or increased discharges	Х			
h.	All discharges are permitted	Х			
i.	Number and location of discharge points are as described in permit		Х		

Comments: i. Outfall 012 is not a direct discharge, it discharges to pond 08.

F. COMPLIANCE SCHEDULES/VIOLATIONS

		Yes	No	NA	ME
a.	Any significant violations since the last inspection		Х		
b.	Permittee is taking actions to resolve violations			Х	
C.	Permittee has compliance schedule		Х		
d.	Compliance schedule contained in:			Х	
e.	Permittee is meeting compliance schedule			Х	

Comments:

G. OPERATION AND MAINTENANCE

Tre	atment Facility Properly Operated and Maintained	Yes	No	NA	ME
a.	Standby power available: Generator: Dual Feed:		Х		
b.	Adequate alarm system available for power or equipment failures	Х			
C.	All treatment units in service other than backup units	Х			
d.	Sufficient operating staff provided: No. of shifts: 1 Days/Week: 5	Х			
e.	Operator holds unexpired license of class required by permit Class:	Х			
f.	Routine and preventive maintenance schedule/performed on time	Х			
g.	Any major equipment breakdown since last inspection		Х		
h.	Operation and maintenance manual provided and maintained		Х		
i.	Any plant bypasses since last inspection		Х		
j.	Regulatory agency notified of bypasses: on MORS800 No.			Х	
k.	Any hydraulic and/or organic overloads experienced since last inspection		Х		

Comments: It is recommended that AEC hire a consultant to troubleshoot the sewage treatment plant.